



THRUST BLOCKING AT VALVES  
16" AND LARGER

16" MAIN - 1 THRUST BLOCK  
REQUIRED, ON MAINS GREATER THAN  
16" - 2 THRUST BLOCKS REQUIRED.

CITY OF RALEIGH				
DEPARTMENT OF PUBLIC UTILITIES				
STANDARD THRUST BLOCK INSTALLATION FOR 16" AND LARGER VALVES AND DEAD END MAINS				
DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-8	Y.C.A.	4-12-90	D.W.C.	9-7-99
		6-92	RRH	3-31-00