



**\*\* service stubout length on residential property and minor text edits. curb stop added**

**NOTES:**

1. WATER METER AS MANUFACTURED BY SENSUS, OR SCHLUMBERGER.
2. DIRECT TAP ALLOWED ON MAINS NO LARGER THAN 16" LINE.
3. METER BOX TO BE LOCATED IN RW ADJACENT TO PROPERTY OR IN APPROVED EASEMENT ADJACENT TO RW.
4. WHEN THE GRADE CHANGES ON EXISTING SERVICES, A COPPER RESETTER CAN BE USED TO ADJUST TO GRADE. COPPER RESETTERS ARE PROHIBITED ON NEW SERVICES.
5. CURB STOP BOX SHALL HAVE PLUG STYLE LID WITH PENTAGON BOLT, 1-1/4" STEEL UPPER SECTION, AND ARCH STYLE BASE. STEEL STATIONARY ROD TO BE PROVIDED FOR CURB STOP OPERATION.

CITY OF RALEIGH  
DEPARTMENT OF PUBLIC UTILITIES

**STANDARD 3/4" & 1" WATER SERVICE INSTALLATION**

DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-23	ABB	4-6-04	RKV	7/23/13
	D.H.L.	6/18/08		