



NOTES:

1. Remove tee fitting, repair stub with curb stop & valve box if not existing.
2. Work to be performed by licensed utility contractor, Stub permit inspection required.
3. For repair of existing service, one brass compression coupling and type K copper as needed to be used for repair.
4. Remove meter box and piping. (Prior to termination the meter division / utility billing must be contacted for meter removal & account closure).

CITY OF RALEIGH
DEPARTMENT OF PUBLIC UTILITIES

Irrigation Meter Termination

DWG. NO.	REVISIONS	DATE	REVISIONS	DATE
W-35T			R.K.V.	6/24/13